

SECTION 00 91 13.1 ADDENDUM #1

1.1 PROJECT INFORMATION

- A. 15th Street Utility Undergrounding and Conduit Bank
- B. Owner: Capital City Development Corporation
- C. Date of Addendum: March 8, 2019

1.2 NOTICE TO BIDDERS

- A. This addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and any previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated in the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum, at same time and location.
 - 1. Bid Date: March 14, 2019 by 3:00 p.m. local time

1.3 REVISIONS TO DIVISION 00 PROCUREMENT AND CONTRACTING REQUIREMENTS

- A. Document 00 01 10 TABLE OF CONTENTS: Revised to insert line 00 91 13.1 ADDENDUM #1.

1.4 REVISIONS TO THE DRAWING SHEETS

- A. Sheet E2.2 – ELECTRICAL PLAN – IDAHO TO BANNOCK
 - 1. Revised to add Electrical Lighting Plan and corresponding Keynote 6.

1.5 PRE-BID MEETING

- A. The following questions were asked at the non-mandatory Pre-Bid Meeting on February 27, 2019. The following answers are provided by Owner to assist Bidders.
 - 1. **QUESTION:** Can we use directional boring?

ANSWER: Conduit installation by directional boring is acceptable,
as long as the installation meets the design intent.

<u>LIST OF DOCUMENTS</u>	<u>NO. OF PAGES</u>
• This Addendum #1 issued March 8, 2019	2
• Pre-Bid Conference Agenda	1
• Pre-Bid Conference Sign-In Sheet	1
• Drawings – revised sheet E2.2, dated 3-1-2019	1

END OF SECTION 00 91 13.1



15th Street Utility Undergrounding and Conduit Bank

Pre-Bid Conference Agenda (15th & Front St – behind Fire Station #5)

February 27, 2019 2:00 P.M.

1. Welcome and Introductions
2. Scope of Work
3. Key Dates
 - Final day for Questions: 5:00 p.m. Wednesday, March 6, 2019
 - Questions must be in writing to Kathy kwanner@ccdcboise.com ,
copy to: Matt Edmond medmond@ccdcboise.com
 - Objections to Specifications / Bidding process: 5:00 p.m. March 11, 2019
 - Due Date: March 14, 2019 3:00 p.m.
4. Submittal Requirements
 - 00 41 13 Bid Form
 - 00 43 22 Unit Prices Bid Form
 - 00 45 46 Contractor's Affidavit Concerning Taxes
 - Bid security required (5%)

Public Works License is required
5. Review of Plans and Specifications
6. Questions



15th Street Utility Undergrounding and Conduit Bank

Pre-Bid Meeting February 27, 2019 AT 2:00 p.m.
15th & Front Street (behind Fire Station #5)

Sign-In Sheet

Name	Company	Telephone Number	Email Address
Mike Uranga	Anderson & Wood	208-888-7917	muranga@awconst.com
Jason Minnick	Anderson & Wood	208-810-0886	jminnick@awconst.com
Bernie Ashe	"	208-866-1786	bushie@AWCONST.COM
Bob Hall	Circle H Const.	208-859-7781	Andy Clapier & msn.com
Rob Cloninger	Gutho Corp	208-841-4712	Rob@GuthoCorp.com
Mark Peterson	Ground Innovations	208 870-3220	mark@GroundInnovationsLLC.com
Ricardo Zavala	Quadrant Consulting	208-342-0091	ricarb@quadrant.ca
Kathy Wanner	CCDC	208-384-4264	kwanner@ccdcboise.com
Matt Edmond	CCDC	208-384-4264	medmond@ccdcboise.com



- A. CONTRACTOR SHALL COORDINATE WITH AN UNDERGROUND LOCATING SERVICE PRIOR TO COMMENCING WORK. COORDINATE WITH OTHER SITE DISCIPLINES.
- B. ROUTE CONDUITS IN COMMON TRENCH WHERE POSSIBLE REFER TO TRENCHING DETAIL. RE:TRENCHING DETAIL.
- C. SEE CIVIL DRAWINGS FOR ADDITIONAL INFORMATION.
- D. SITE LIGHTING AND UTILITY EQUIPMENT SHOWN IN APPROXIMATE LOCATION. COORDINATE EXACT LOCATION WITH CIVIL DRAWINGS, PROPERTY LINES, AND UTILITY COMPANIES PRIOR TO ROUGH-IN.
- E. PROVIDE PULL-LINE IN ALL EMPTY CONDUITS.



KEYED NOTES:

- # SYMBOL USED FOR NOTE CALLOUT.
1. APPROXIMATE LOCATION OF IDAHO POWER TRANSFORMER BY IDAHO POWER.
 2. PROVIDE AND INSTALL 2" CONDUIT WITH #210, 1#66 FROM THE IDAHO POWER TRANSFORMER TO THE METERING CABINET. COORDINATE ROUTING WITH CIVIL AND INSTALLATION WITH IDAHO POWER.
 3. NEW STREET LIGHTING METERING PEDESTAL "M" PER THE CITY OF BOISE STANDARDS.
 4. STUB (4)" CONDUITS TO THIS AREA FOR FUTURE USE.
 5. (2)1" CONDUITS WITH 3#6, 1#6G EACH.
- △ 30 FOOT COBRA HEAD STREET LIGHT, SL1, REFER TO LIGHT FIXTURE SCHEDULE AND BOISE CITY STANDARDS FOR REQUIREMENTS.

LIGHTING FIXTURE SCHEDULE (19-016)						
TYPE	DESCRIPTION	MTG.	LAMPS	WATTS	MFG. & CATALOG NUMBER	OR EQUAL BY
SL1	STREET LIGHT FIXTURE, LED 15' MAST ARM, CLASS B BLACK FINISH	POLE MOUNTED +30'-0"	LED	104	SEE APPROVED PART NUMBER LISTING FOR CITY OF BOISE STREET LIGHTING ON PLANS	
<u>LIGHTING FIXTURE SCHEDULE NOTES:</u>						