

## SECTION 00 91 13.2 ADDENDUM #2

### 1.1 PROJECT INFORMATION

- A. Production and Gowen Road Utilities Project
- B. Owner: Capital City Development Corporation
- C. Date of Addendum: August 5, 2021

### 1.2 NOTICE TO BIDDERS

- A. This addendum serves to clarify, revise, and supersede information in the Project Manual, Special Provisions, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated in the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.

### 1.3 REVISIONS TO DIVISION 00 PROCUREMENT AND CONTRACTING REQUIREMENTS

- A. Document 00 01 10 TABLE OF CONTENTS: Revised to insert line 00 91 13.2 ADDENDUM #2

### 1.4 REVISIONS TO DRAWING SHEETS

- A. Drawing SHT02.DWG - Sheet 2 of 7
  - 1. Revision to Manhole/Vault Installation Requirements
    - a. Note 6.1. Material: Change to Traffic Rated Cast Iron Frame and Cover.
    - b. Note 6.2. Cover Type: Manhole Frame and Cover

### 1.5 QUESTIONS AND ANSWERS

- A. The following questions regarding the Project have been submitted. The following answers are provided by the Engineer to assist Bidders.
  - 1. Regarding bid Item 308.4.1.A.1 - 10" Dia. 3/8" Thick steel casing pipe boring and jacking: Could it instead be a bored 10" poly pipe with the 8- 1 1/4" and 2-2" conduits in it?  
**ANSWER:** No. The steel casing is required by the UPRR.

#### LIST OF DOCUMENTS

#### NO. OF PAGES

This Addendum #2 issued August 5, 2021

1

END OF SECTION 00 91 13.2

ADDENDUM #2 AUGUST 5, 2021

00 91 13.2 - 1