

## SECTION 00 91 13.1 ADDENDUM #1

### 1.1 PROJECT INFORMATION

- A. CAPITOL & MYRTLE GARAGE STRUCTURAL REPAIRS PROJECT
- B. Owner: Capital City Development Corporation
- C. Date of Addendum: June 26, 2024

### 1.2 NOTICE TO BIDDERS

- A. This Addendum is issued pursuant to the Conditions of the Contract. This addendum serves to clarify, revise, and supersede information in the Project Manual and Drawings. Portions of the Addendum affecting the Contract Documents will be incorporated in the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum, at same time and location.
  - 1. Bid Date: July 2, 2024 by 3:00 pm

### 1.3 REVISIONS TO DIVISION 00 PROCUREMENT AND CONTRACTING REQUIREMENTS

- 1. Document 00 01 10 TABLE OF CONTENTS: Revised to insert line 00 91 13.1 ADDENDUM #1

### 1.4 REVISIONS TO DIVISION 01 REQUIREMENTS

#### A. SECTION 01 10 00 SUMMARY OF WORK

- 1. 1.6.A.2.c. Partial Closures, add the following:
  - a. No more than 20 parking stalls may be closed at any time. At least one 10-foot-wide vehicle travel lane shall remain open at all times around the work area and flaggers and/or appropriate traffic control devices and traffic control signage shall be provided any time a drive aisle (or portion thereof) is closed. Contractor may need to utilize parking stall closures to maintain proper vehicle circulation around the work area.

### 1.5 COMPARABLE PRODUCT APPROVAL

- A. Specification 07 18 00 Traffic Coatings

1. Engineer and Owner have approved the use of comparable products for the project. Bidders may use the products stated in the bid specification 07 18 00, OR the following may be used:

<b>Manufacturer</b>	<b>Comparable Product #</b>	<b>Documentation</b>
Sika	Sikadur 22 Lo-Mod FS	See attached
Sika	Sikalastic 720 One Shot	See attached

1.6 PRE-BID MEETING QUESTIONS

- A. The following questions were asked during the bid period. The following answers and clarifications are provided by Owner to assist Bidders.

1. Q: Are the sprinkler fire lines charged or dry?

A: Owner advises Fire Sprinklers are a dry system. Contractor to coordinate with all associated parties any modifications or temporary disruptions.

<u>LIST OF DOCUMENTS</u>	<u>NO. OF PAGES</u>
This Addendum #1 issued June 26, 2024	2
PreBid Agenda	1
PreBid Sign In Sheet	1
Comparable Request/Approval/Documentation	10

END OF SECTION 00 91 13.1



## Capitol & Myrtle Garage Structural Repairs Project

### Pre-Bid Conference Agenda On Site – 445 S. Capitol Boulevard

June 20, 2024 at 11:00 a.m.

#### A. Welcome and Introductions

##### 1. Introductions

- i. Kathy Wanner –CCDC Contracts Manager
- ii. Aaron Nelson – CCDC Parking & Facilities Manager
- iii. Brian Coleman – Hummel – Architect

#### B. Bidding Requirements and Key Dates

1. Final Day for Questions & Clarifications: June 24, 2024 5:00 p.m.  
Questions must be in writing to Kathy Wanner: [kwanner@ccdcbiose.com](mailto:kwanner@ccdcbiose.com)
2. Addendum: June 26, 2024
3. Bid Date: **July 2, 2024 by 3:00 pm**
4. Bid Submission (signed pdfs): [bids@ccdcbiose.com](mailto:bids@ccdcbiose.com)
5. Bid Submittal Requirements
  - i. 00 41 13 Bid Form
  - ii. 00 43 22 Unit Prices Bid Form
  - iii. 00 45 46 Contractor's Affidavit Concerning Taxes
6. Questions

#### C. General Requirements

1. Scope of Work
2. Site Coordination
3. Schedule
4. Questions



Capitol & Myrtle Garage Structural Repairs Project  
 Pre-Bid Meeting June 20, 2024 11:00 a.m.  
 On Site – Capitol & Myrtle Garage, 445 S Capitol Blvd

**Sign-In Sheet**

Name	Company	Telephone Number	Email Address
Kathy Wanner	CCDC	208-391-7304	<a href="mailto:kwanner@ccdcboise.com">kwanner@ccdcboise.com</a>
Aaron Nelson	CCDC	208-384-4264	<a href="mailto:anelson@ccdcboise.com">anelson@ccdcboise.com</a>
Joe Hendricks	CASCADE	208 250-1914	<a href="mailto:Joe.Hendricks@interprises.com">bidding@casca</a>
Zach Pirepnyes	CCDC		
SCOTT LAUSBURG	STRUCTURAL	714 307-6440	<a href="mailto:SCOTT.LAUSBURG@STRUCTURAL.NET">SCOTT.LAUSBURG@STRUCTURAL.NET</a>
CORY BROWN	SPRINTOOTH CONSTRUCTION	971-312-5356	<a href="mailto:CORP@SPRINTOOTHCONSTRUCTION.COM">CORP@SPRINTOOTHCONSTRUCTION.COM</a>
Brett Barrier	Barrier Building	208-320-7716	<a href="mailto:brett@barrierbuilding.com">brett@barrierbuilding.com</a>
Math King	CONSURCO	208-996-9746	<a href="mailto:Matt.King@consurco.com">Matt.King@consurco.com</a>
Joe Chavez	CONSURCO	208-666-0531	<a href="mailto:Joe.Chavez@consurco.com">Joe.Chavez@consurco.com</a>
COREY STANSAUK	CONSURCO	714) 766-5455	<a href="mailto:cory.stansauk@consurco.com">cory.stansauk@consurco.com</a>
Andrew Mitzel	Wright Brothers	208-695-5440	<a href="mailto:amitzel@wrightbrothers.com">amitzel@wrightbrothers.com</a>
Sophie Rodambaugh	BriLion Inc	(208) 599-8432	<a href="mailto:esimating@brilioninc.com">esimating@brilioninc.com</a>
Brian Riley	Talisman Construction Svcs	208-868-1985	<a href="mailto:briley@talisman-services.com">briley@talisman-services.com</a>



**SUBSTITUTION REQUEST**

TO: CCDC

PROJECT: Capital & Myrtle Parking Garage

SPECIFIED ITEM: Traffic Coatings

071800	3	2.1 & 2.3	TRAFFIC COATING
Section	Page	Paragraph	Description

**PROPOSED SUBSTITUTION:** Sikadur 22 LMFS primer & Sikalastic 720 OneShot

Attached data includes product description, specifications, drawings, photographs, performance and test data adequate for evaluation of request. Applicable data is clearly identified.

Attached data also includes description of changes to Contract Documents the proposed substitution requires for its proper installation.

**Undersigned certifies following items, unless modified by attachments, are correct:**

- Proposed substitution does not affect dimensions shown on drawings.
- Undersigned will pay for changes to building design, including engineering design, detailing, and construction costs caused by proposed substitution.
- Proposed substitution has no adverse effect on other trades, construction schedule, or specified warranty requirements.
- Maintenance and service parts are available locally or are readily obtainable for proposed substitution.

**Undersigned further certifies the function, appearance, and quality of the proposed substitution are equivalent or superior to the specified item.**

**Undersigned agrees, if this page is reproduced, the terms and conditions for substitutions found in Bidding Documents apply to this proposed substitution.**

**Submitted by:**

Dan Ficker  
**Name (printed or typed)**

**Signature**

Sawtooth Caulking, Inc.  
**Firm Name**

1445 NE miller St., Bldg C1  
**Address**

McMinnville, OR 97128  
**City, State, Zip**

//  
**Date**

503-560-8559        
**Telephone**                      **Fax**

**General Contractor (If after award of Contract)**

<b>For use by A/E</b>	
<input checked="" type="radio"/> <b>Approved</b>	<input type="radio"/> <b>Approved as Noted</b>
<input type="radio"/> <b>Not Approved</b>	<input type="radio"/> <b>Received Too Late</b>
By <u>Brian Coleman, Hummel Architects</u>	
Date <u>06.25.2024</u>	
Remarks _____	
_____	
_____	

**List of Attachments:**

## PRODUCT DATA SHEET

# Sikadur<sup>®</sup>-22 Lo-Mod FS

LOW-MODULUS, FAST SETTING, MEDIUM-VISCOSITY, EPOXY RESIN BINDER

### PRODUCT DESCRIPTION

Sikadur<sup>®</sup>-22 Lo-Mod FS is a 2-component, 100% solids, moisture-tolerant, fast setting epoxy resin binder. It conforms to the current ASTM C-881, Type III, Grade 1, Class C and AASHTO M-235 specifications.

### USES

Sikadur<sup>®</sup>-22 Lo-Mod FS may only be used by experienced professionals.

Use neat as the binder resin for a skid-resistant broadcast overlay. Use also as the binder resin for epoxy mortar and concrete for patching and overlays.

### CHARACTERISTICS / ADVANTAGES

- Fast Setting for quick turn around
- Meets 3 h/1000 psi requirement when mixed as an epoxy mortar
- Tolerant to moisture both before and after cure
- Convenient easy mix ratio A:B = 1:1 by volume
- Excellent strength development
- Leveling viscosity for easy, efficient application of a broadcast overlay
- Successfully used in HFST applications. Refer to local DOT specifications for product acceptance

### PRODUCT INFORMATION

Chemical Base	Epoxy Resin
Packaging	4 gallon (15 L) units / 110 gallon (416 L) unit / 660 (2498 L) gallon totes. <b>Note: Part A of the Sikadur<sup>®</sup> 22 Lo-Mod, Sikadur<sup>®</sup>-22 Lo-Mod FS and Sikadur<sup>®</sup> 21 Lo-Mod LV is a universal component of these three products.</b>
Color	Clear to light amber
Shelf Life	24 months in original, unopened containers
Storage Conditions	Store dry at 40–95 °F (4–35 °C) Condition material at 65–85 °F (18–29 °C) before using.
Volatile organic compound (VOC) content	<20 g/L
Viscosity	Approximately 2,000 cps

## TECHNICAL INFORMATION

<b>Shore D Hardness</b>	72			(ASTM D-2240) 73 °F (23 °C) 50 % R.H.	
<b>Compressive Strength</b>		<b>40 °F(4 °C)</b>	<b>73 °F (23 °C)</b>	<b>90 °F (32 °C)</b>	(ASTM C-579)
	3 hours	-	1750 psi	3600 psi	
	8 hours	2000 psi	4400 psi	6400 psi	
	1 day	4500 psi	6500 psi	8000 psi	
	3 days	5500 psi	7500 psi	8500 psi	
	7 days	8500 psi	8500 psi	9000 psi	
	14 days	9000 psi	9000 psi	9000 psi	
	28 days	9000 psi	9000 psi	9000 psi	
Material cured and tested at the temperatures indicated and 50 % R.H.					
<b>Modulus of Elasticity in Compression</b>	7 days		40,000 psi		(ASTM C-579) 73 °F (23 °C) 50 % R.H.
	28 days		40,000 psi		
<b>Tensile Strength</b>		<b>Mortar 1:3</b>	<b>Neat</b>		(ASTM D-638) 73 °F (23 °C) 50 % R.H.
	7 day	1200 psi	2650 psi		
<b>Elongation at Break</b>		<b>Mortar 1:3</b>	<b>Neat</b>		(ASTM D-638) 73 °F (23 °C) 50 % R.H.
	7 day	40 %	55 %		
<b>Tensile Adhesion Strength</b>		<b>Mortar 1:3</b>	<b>Neat</b>		(ASTM C-1583; ACI 503R) 73 °F (23 °C) 50 % R.H.
	1 day	-	> 550 psi (concrete failure)		
	7 days	-	> 570 psi (concrete failure)		
<b>Shear Strength</b>		<b>Mortar 1:3</b>	<b>Neat</b>		(ASTM D-732) 73 °F (23 °C) 50 % R.H.
	7 day	2600 psi	3430 psi		
<b>Thermal Compatibility</b>	Pass				(ASTM C-884)
<b>Abrasion Resistance</b>		<b>Mortar 1:3</b>	<b>Neat</b>		(Taber Abrader) 73 °F (23 °C) 50 % R.H.
	14 day, Weight loss, 1,000 cycles*	2.0 grams	0.030 grams		
* (H-22 wheel; 1,000 gm weight for mortar/ C-17 wheel, 1,000 gm wt for neat)					
<b>Water Absorption</b>		<b>Mortar 1:3</b>	<b>Neat</b>		(ASTM D-570) 73 °F (23 °C) 50 % R.H.
	7 day (24 hour immersion)	-	< 0.20 %		
<b>Rapid Chloride Permeability</b>	0 coulombs				(AASHTO T-277)

## APPLICATION INFORMATION

<b>Mixing Ratio</b>	Component 'A': Component 'B' = 1:1 by volume.
<b>Coverage</b>	1 gal. yields 231 in <sup>3</sup>
	<b>Mortar Binder</b> - 1 gal. of mixed Sikadur® 22 Lo-Mod FS with the addition of 5

gal. by loose volume of an oven dried sand, yields approximately 808 cu. in. of epoxy mortar

<b>Pot Life</b>	Approximately 15–20 minutes		(60 gram mass; ASTM C-881)
<b>Waiting / Recoat Times</b>	<b>60–64 °F (16-18 °C)</b>	<b>65–69 °F (19-21 °C)</b>	<b>70–74 °F (21-23 °C)</b>
	Coat 1	4–4 ½ h	2 ½–3 h
	Coat 2	5 ½–6 h	4 h
	<b>75–79 °F (24-26 °C)</b>	<b>80–84 °F (27-29 °C)</b>	<b>85+ °F (29+ °C)</b>
	Coat 1	2 h	1.5 h
	Coat 2	3 h	2 ½–3 h

Average Substrate and Material Temperature. These set times were determined under laboratory conditions, actual set times may vary based on on-site conditions

## APPLICATION INSTRUCTIONS

finishing trowel. Priming is mandatory when using the Sikadur®-22 Lo-Mod FS as an epoxy mortar.

### SUBSTRATE PREPARATION

Surface must be clean and sound. It may be dry or damp, but free of standing water. Remove dust, laitance, grease, curing compounds, impregnations, waxes and any other contaminants.

**Preparation Work: Concrete** - Should be cleaned and prepared to achieve a laitance and contaminant free, open textured surface by blast cleaning or equivalent mechanical means.

**Steel** - Should be cleaned and prepared thoroughly by blast cleaning to white metal finish.

### MIXING

Mixing Pre-mix each component. Proportion equal parts by volume of Component 'A' and 'B' into clean pail. Mix thoroughly for 3 min. with Sika paddle on low-speed (400–600 rpm) drill until uniformly blended. Mix only that quantity that can be used within pot life.

**To prepare epoxy mortar** - Slowly add 5 parts by loose volume of oven-dried sand to 1 part mixed resin.

### APPLICATION METHOD / TOOLS

**Broadcast Overlay** - Prime the prepared substrate with Sikadur®-22 Lo-Mod FS. While primer is still tacky, spread mixed Sikadur®-22 Lo-Mod FS with a 3/16 in. (4.7 mm) notched squeegee. When material levels, broadcast the oven-dried aggregate slowly allowing it to settle in the epoxy binder.

Ultimately the broadcast aggregate should be applied to excess at a rate of 2 lb./ft² (0.9 kg/m²) Remove excess broadcast aggregate after epoxy has set. Priming is an optional step in the broadcast overlay applications.

**Epoxy Mortar** - Prime prepared substrate with mixed Sikadur®-22 Lo-Mod FS. While primer is still tacky, apply epoxy mortar by trowel or vibrating screed. Finish with



## LIMITATIONS

- Minimum substrate and ambient temperature 40 °F (4 °C).
- Minimum age of concrete before application is 21–28 days depending upon curing and drying conditions.
- For on grade, split-slab and unvented metal pan deck, please consult Sika Technical Service regarding moisture limitations.
- Maximum thickness 1/2 in. (13 mm) exterior exposed to thermal change.
- Do not dilute. Addition of solvents will prevent proper cure.
- Use oven-dried aggregates only.
- Material is a vapor barrier after cure.
- Not an aesthetic product. Color may alter due to variations in lighting and/or UV exposure.
- For HFST applications, system and application details are governed by local DOT & AASHTO specification.

## BASIS OF PRODUCT DATA

Results may differ based upon statistical variations depending upon mixing methods and equipment, temperature, application methods, test methods, actual site conditions and curing conditions.

## OTHER RESTRICTIONS

See Legal Disclaimer.

## ENVIRONMENTAL, HEALTH AND SAFETY

For further information and advice regarding transportation, handling, storage and disposal of chemical products, user should refer to the actual Safety Data Sheets containing physical, environmental, toxicological and other safety related data. User must read the current actual Safety Data Sheets before using any products. In case of an emergency, call CHEMTREC at 1-800-424-9300, International 703-527-3887.

## LEGAL DISCLAIMER

- KEEP CONTAINER TIGHTLY CLOSED
- KEEP OUT OF REACH OF CHILDREN
- NOT FOR INTERNAL CONSUMPTION
- FOR INDUSTRIAL USE ONLY
- FOR PROFESSIONAL USE ONLY

Prior to each use of any product of Sika Corporation, its

### Sika Corporation

201 Polito Avenue  
Lyndhurst, NJ 07071  
Phone: +1-800-933-7452  
Fax: +1-201-933-6225  
usa.sika.com

### Sika Mexicana S.A. de C.V.

Carretera Libre Celaya Km. 8.5  
Fracc. Industrial Balvanera  
Corregidora, Queretaro  
C.P. 76920  
Phone: 52 442 2385800  
Fax: 52 442 2250537



### Product Data Sheet

Sikadur®-22 Lo-Mod FS  
April 2020, Version 01.02  
020204030010000143

subsidiaries or affiliates ("SIKA"), the user must always read and follow the warnings and instructions on the product's most current product label, Product Data Sheet and Safety Data Sheet which are available at [usa.sika.com](http://usa.sika.com) or by calling SIKA's Technical Service Department at 1-800-933-7452. Nothing contained in any SIKA literature or materials relieves the user of the obligation to read and follow the warnings and instructions for each SIKA product as set forth in the current product label, Product Data Sheet and Safety Data Sheet prior to use of the SIKA product.

SIKA warrants this product for one year from date of installation to be free from manufacturing defects and to meet the technical properties on the current Product Data Sheet if used as directed within the product's shelf life. User determines suitability of product for intended use and assumes all risks. User's and/or buyer's sole remedy shall be limited to the purchase price or replacement of this product exclusive of any labor costs. **NO OTHER WARRANTIES EXPRESS OR IMPLIED SHALL APPLY INCLUDING ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SIKA SHALL NOT BE LIABLE UNDER ANY LEGAL THEORY FOR SPECIAL OR CONSEQUENTIAL DAMAGES. SIKA SHALL NOT BE RESPONSIBLE FOR THE USE OF THIS PRODUCT IN A MANNER TO INFRINGE ON ANY PATENT OR ANY OTHER INTELLECTUAL PROPERTY RIGHTS HELD BY OTHERS.**

Sale of SIKA products are subject to the Terms and Conditions of Sale which are available at <https://usa.sika.com/en/group/SikaCorp/termsandconditions.html> or by calling 1-800-933-7452.

Sikadur-22Lo-ModFS-en-US-(04-2020)-1-2.pdf





## PRODUCT DATA SHEET

# Sikalastic®-720 One Shot

TWO-COMPONENT, INTEGRAL TEXTURE, FAST CURING, EXTREMELY DURABLE, ONE STEP POLY-URETHANE TRAFFIC COATING SYSTEM.

### PRODUCT DESCRIPTION

Sikalastic®-720 One Shot is a two-component, integral texture, fast-curing, aliphatic, chemically cured, elastomeric polyurethane waterproofing coating intended for vehicular and pedestrian traffic. Applied in a single step the Sikalastic®-720 One Shot system replaces the standard traffic coating systems of a base coat and multiple top-coats. Sikalastic®-720 One Shot meets the requirements of ASTM C957 "Standard Specification for High-Solids Content, Cold Liquid Applied Elastomeric Waterproofing Membrane with Integral Wearing Surface."

### USES

Sikalastic®-720 One Shot may only be used by experienced professionals.

Typical applications include:

- Multi-story parking garages
- Parking decks and ramps
- Foot bridges and walkways
- Mechanical rooms
- Stadiums and arenas
- Plaza and rooftop decks

### PRODUCT INFORMATION

<b>Packaging</b>	9.6 gal two component kit, 2x 4.32 gal. comp. A with aggregate insert, 2x 0.48 gal. comp. B
<b>Color</b>	Available in Gray and Charcoal
<b>Shelf Life</b>	1 year in original, unopened containers.

### CHARACTERISTICS / ADVANTAGES

- Achieves a 45 mil system in one single coat application
- Integral Texture for superior durability
- Outstanding resistance to abrasion and wear
- Fast turnarounds - open to traffic in 36 hours!
- Full Aliphatic system- UV resistance throughout
- Resistant to deicing salts

### APPROVALS / STANDARDS

- Meets ASTM C957 "Standard Specification for High-Solids Content, Cold Liquid-Applied Elastomeric Waterproofing Membrane With Integral Wearing Surface".

<b>Storage Conditions</b>	Store dry at 41-95 °F (5-35 °C). Condition material to 65-85 °F (18-30 °C) before using.	
<b>Solid content by volume</b>	95% including aggregate	
<b>Volatile organic compound (VOC) content</b>	<100 g/L	

## TECHNICAL INFORMATION

<b>Shore A Hardness</b>	90+/- 5	(ASTM D-2240) 75°F (24°C) 50 % R. H								
<b>Tensile Strength</b>	2400 psi +/- 100	(ASTM D-412) 75°F (24°C) 50 % R. H								
<b>Elongation at Break</b>	500 % +/- 50%	(ASTM D-412) 75°F (24°C) 50 % R. H								
<b>Tensile Adhesion Strength</b>	<table border="1"> <thead> <tr> <th>Primer</th> <th>Failure Mode</th> </tr> </thead> <tbody> <tr> <td>Sikalastic-MT Primer</td> <td>Substrate (Concrete)</td> </tr> <tr> <td>Sikadur-22 LM FS</td> <td>Substrate (Concrete)</td> </tr> <tr> <td>Sikadur- 57 LM</td> <td>Substrate (Concrete)</td> </tr> </tbody> </table>	Primer	Failure Mode	Sikalastic-MT Primer	Substrate (Concrete)	Sikadur-22 LM FS	Substrate (Concrete)	Sikadur- 57 LM	Substrate (Concrete)	(ASTM D-4541) 75°F (24°C) 50 % R. H
Primer	Failure Mode									
Sikalastic-MT Primer	Substrate (Concrete)									
Sikadur-22 LM FS	Substrate (Concrete)									
Sikadur- 57 LM	Substrate (Concrete)									
<b>Tear Strength</b>	300 pli +/- 50	(Die C, ASTM D-624) 75°F (24°C) 50 % R. H								

## APPLICATION INFORMATION

<b>Coverage</b>	33 sf/gal 158 sf/ 4.8 gal A+B mix
<b>Layer Thickness</b>	45 mils dry (48 WFT)
<b>Pot Life</b>	20 min at 75°F (24°C) 50 % R. H

## BASIS OF PRODUCT DATA

Results may differ based upon statistical variations depending upon mixing methods and equipment, temperature, application methods, test methods, actual site conditions and curing conditions.

Results may differ based upon statistical variations depending upon mixing methods and equipment, temperature, application methods, test methods, actual site conditions and curing conditions.

## LIMITATIONS

- Do not apply in conditions when concrete is outgassing and has potential to cause pinholing in the system.
- To avoid dew point conditions during application relative humidity must be no more than 95 % and substrate temperature must be at least 5 °F (3 °C) above measured dew point temperature.
- Maximum moisture content of concrete substrate by weight when measured with a Tramex CME is 4%. If higher then see primer requirements for proper application.
- Minimum ambient and substrate temperature during application and curing of material is 40 °F (4 °C); maximum is 95 °F (35 °C).
- Do not store materials outdoors directly exposed to sunlight and moisture. Cover and protect materials with breathable type covers such as canvas tarpaulins to allow venting and protection from weather and moisture. Observe temperature storage and conditioning requirements.
- Do not thin with solvents.
- Minimum age of concrete must be 21–28 days, depending on curing and drying conditions.
- Any repairs required to achieve a level surface must be

performed prior to application (consult a Sika representative for guidance on various product solutions). Surface irregularities may reflect through the cured system and should be mitigated.

- Do not apply to a porous or damp surface where moisture vapor transmission will occur during application and cure.
- Substrate must be dry prior to application. Do not apply to a frosted, wet or damp surface.
- Do not proceed if rain is imminent within 6–12 hours of application. Allow sufficient time for the substrate to dry after rain or inclement weather as there is the potential for bonding problems.
- When applying over existing coatings compatibility and adhesion testing is required.
- Precautions should be taken to prevent odors and/or vapors from entering the building/structure, including but not limited to turning off and sealing air intake vents or other means of ingress for odors and for vapors into the building/structure during product application and cure.
- On grade, lightweight concrete, asphalt pavement, or insulated split slab applications, or applications where chained or studded tires may be used, must not be coated with Sikalastic Traffic Systems without Sika technical review. Contact Sika Technical Services or Product Engineering.
- Unvented metal pan decks or decks containing a between-slab membrane require further technical evaluation and priming with a moisture tolerant primer - contact Sika regarding recommendations.
- Waterproofing applications under overburden, including concrete pavement, and tile in a cementitious setting bed, require further technical evaluation - contact Sika regarding recommendations.
- Do not subject to ponding water or continuous immersion.
- Mockups to verify application methods and substrate conditions as well as desired skid resistance and aesthetics are highly recommended.

## ENVIRONMENTAL, HEALTH AND SAFETY

For further information and advice regarding transportation, handling, storage and disposal of chemical products, user should refer to the actual Safety Data Sheets containing physical, environmental, toxicological and other safety related data. User must read the current actual Safety Data Sheets before using any products. In case of an emergency, call CHEMTREC at 1-800-424-9300, International 703-527-3887.

## APPLICATION INSTRUCTIONS

### SUBSTRATE PREPARATION

Surface must be clean, dry and sound with an open texture. Remove dust, laitance, grease, curing compounds, bond inhibiting impregnations, waxes, and any other contaminants. All projections, rough spots, etc., must be removed to achieve a level surface prior to

the application.

**Concrete** - Must be cleaned and prepared to achieve a laitance and contaminant-free, open-textured surface by blast cleaning or equivalent mechanical means. The desired surface texture is CSP 3 per ICRI Guidelines. In addition, the substrate surface must be thoroughly cleaned by blowing/vacuuming to remove all particulates that may interfere with coat bonding.

**Plywood** – Must be clean and smooth, APA and exterior grade, not less than ½” thick, and spaced and supported according to APA guidelines. Joints should be sealed with Sikaflex® 2c NS EZ Mix or Sikaflex® 1a and detailed, and may need embedded fabric reinforcement.

**Metal** - Must be thoroughly cleaned by grinding or blast cleaning. Sikalastic EP Primer is recommended to be used for proper adhesion and corrosion protection.

### DETAILING

**Non-structural cracks up to 1/16 inch** – Apply a detail coat of a Sikalastic® Base Coat at 23 mils wet, 4” wide, centered over the crack. Allow to become tack free before overcoating.

**Cracks and joints over 1/16 up to 1 inch** – Seal previously routed and primed cracks and joints with Sika Sealant and allow to skin over and cure for 24 hours min. Apply a detail coat of a Sikalastic® Base Coat at 23 mils wet, 4” wide, centered over the crack. Allow to become tack free before overcoating.

**Joints over 1 inch** – Should be treated as expansion joints and brought up through the Sikalastic® 720 One Shot Traffic System and sealed with Sika sealant (see Sealant Guide).

### PRIMING

**Primer Selection** - Primer is required for all applications of Sikalastic®-720 One Shot. For applications over concrete, the primer used will depend on the moisture level of the concrete. Measure the moisture content of concrete substrate with a Tramex CME or CMExpert type concrete moisture meter.

**Sikadur®-22 Lo-Mod FS-** For concrete with a maximum moisture content of 4 % by weight and existing polyurethane coatings, apply a single coat application of Sikadur®-22 Lo-Mod FS with a flat squeegee or roller at approximately 160 sf/gal. Apply evenly without puddling. Allow primer to cure until tack-free, typically 2-4 hours (at 75°F (24°C) 50 % R. H). Sikadur®-22 Lo-Mod FS should be overcoated within 36 hours after tack-free. Refer to a separate product data sheet for additional information.

**Sikalastic® FTP LoVOC Primer** - For plywood decks, concrete with a maximum moisture content of 5 % by weight, apply a single coat application of Sikalastic® FTP LoVOC Primer with a flat squeegee or roller at approximately 175 sf/gal. For concrete decks with a maximum moisture content of 6% by weight, apply two applications of Sikalastic® FTP LoVOC Primer with a flat squeegee or phenolic resin roller at approximately 175 - 220 sf/gal per application. Work primer well into the substrate to ensure adequate penetration and sealing. Apply evenly without puddling. Refer to separate primer

data sheet for additional information.

**Sikalastic® MT Primer** - For concrete with a maximum moisture content of 5 % by weight, and for metal flanges and penetrations, apply a single coat application of Sikalastic® MT Primer with a flat squeegee or roller at approximately 175 sf/gal. For concrete decks with a maximum moisture content of 6% by weight, apply two applications of Sikalastic® MT Primer with a flat squeegee or phenolic resin roller at approximately 175 sf/gal per application. Work primer well into the substrate to ensure adequate penetration and sealing. Apply evenly without puddling. Refer to a separate primer data sheet for additional information.

**Sikalastic® EP Primer/Sealer**- For Wood (timber, plywood) and Metal (aluminum, galvanized, cast iron, copper, lead, brass, stainless steel, steel, zinc). Apply by brush or phenolic resin core roller at the recommended rate, 100-250 sf/gal depending on the substrate. Correct amount of primer will saturate the substrate and leave a slight film on the substrate top surface. Apply evenly without puddling. Refer to separate primer data sheet for additional information.

**Sikadur®-22 Lo-Mod LT**- For cold weather applications on concrete with a maximum moisture content of 4 % by weight and existing polyurethane coatings, apply a single coat application of Sikadur®-22 Lo-Mod LT with a flat squeegee or roller at approximately 160 sf/gal. Apply evenly without puddling. Allow primer to cure until tack-free, typically 2-4 hours (at 50°F (10°C) 50 % R. H). Sikadur®-22 Lo-Mod LT should be overcoated within 36 hours after tack-free. Refer to a separate product data sheet for additional information.

**Sikadur®-57 Lo-Mod LV**- For concrete with a maximum moisture content of 4 % by weight, apply a single coat application of Sikadur®-57 Lo-Mod LV with a flat squeegee or roller at approximately 125-150 sf/gal. Apply evenly without puddling. Refer to a separate product data sheet for additional information.

**Sikalastic® Primer** – For existing polyurethane coatings only, apply Sikalastic® Primer with a flat squeegee or phenolic resin core roller at approximately 300 sf/gal. Work primer well into the substrate to ensure adequate penetration and sealing. Apply evenly without puddling. Sikalastic® Primer is not suitable for metal substrates. Refer to a separate primer data sheet for additional information.

## MIXING

After opening Part A place lid face up on ground, remove aggregate insert and place insert on pail lid. Premix Part A component using a low speed (400–600 rpm) mechanical mixer and Jiffy Paddle (5-50 gal. model) at slow speed to obtain uniform color. Slowly add aggregate from tray into Part A and continue to mix, making sure to scrape the bottom and sides of the pail, ensure aggregate is fully mixed within the Part A. Slowly pour Part B into Part A while mixing so that the Part B gets pulled into the vortex of the mixing paddle. Scrape the sides of the container, Mix the combined material thoroughly for 3 minutes until a homogenous mixture and uniform color is obtained. Use care not to prevent whipping air into the material while mixing - use a slow and methodical mixing approach.

## APPLICATION METHOD / TOOLS

After mixing, immediately pour the mixed Sikalastic®-720 One Shot onto the substrate. Leaving the Sikalastic®-720 One Shot in the pail will shorten the working time and pot life and will result in loss of material. Material should be poured out in a ribbon fashion and not in one large puddle. This will help make sure to get the most effective squeegee application. Apply Sikalastic®-720 One Shot over the entire area including previously detailed cracks. Coating should be tack free after about 6 hours at 70 °F and 50 % RH. Allow coating to cure for a minimum of 36 hours before opening to vehicular traffic

**Proper Squeegee:** Use a 3/8" notched squeegee or trowel to achieve the proper wet film thickness of 48 mils (45 mill DFT). The squeegee must be stiff enough to not bend when significant pressure is placed on it - this will result in improper thickness. It is highly recommended to check thickness with a wet film gage as work is progressing.

**Proper Roller:** Phenolic resin core roller with 3/8" Nap  
**Squeegee Application and Finish Rolling:** Push squeegee behind ribbon of material with consistent pressure on squeegee, do not pull squeegee towards applicator. After squeegeeing material to proper thickness, backroll material in **two directions**; one perpendicular to the other. Wet roller with excess material prior to backrolling, using a dry roller for backrolling will result in improper application thickness. Do not apply pressure with roller, do not push material with roller. If backrolled more than one time in each direction final texture could be inconsistent.

## CLEANING OF TOOLS

Clean tools with solvent that is acceptable to be used based on local regulations. Xylene, Acetone and MEK, if accepted locally are effective for cleaning tools and equipment.

## OTHER RESTRICTIONS

See Legal Disclaimer.

## LEGAL DISCLAIMER

**KEEP CONTAINER TIGHTLY CLOSED •KEEP OUT OF REACH OF CHILDREN •NOT FOR INTERNAL CONSUMPTION •FOR INDUSTRIAL USE ONLY •FOR PROFESSIONAL USE ONLY**

Prior to each use of any product of Sika Corporation, its subsidiaries or affiliates ("SIKA"), the user must always read and follow the warnings and instructions on the product's most current product label, Product Data Sheet and Safety Data Sheet which are available at [usa.sika.com](http://usa.sika.com) or by calling SIKA's Technical Service Department at 800-933-7452. Nothing contained in any SIKA literature or materials relieves the user of the obligation to read and follow the warnings and instructions for each SIKA product as set forth in the current product label, Product Data Sheet and Safety Data Sheet prior to use of the SIKA product. SIKA warrants this product for one year from date of installation to be free from manufacturing defects and to meet the technical properties on the current Product Data Sheet if used as directed within the product's shelf life. User determines suitability of product for intended use and assumes all risks. User's and/or buyer's sole remedy shall be limited to the purchase price or replacement of this product exclusive of any labor costs. NO OTHER WARRANTIES EXPRESS OR IMPLIED SHALL APPLY INCLUDING ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SIKA SHALL NOT BE LIABLE UNDER ANY LEGAL THEORY FOR SPECIAL OR CONSEQUENTIAL DAMAGES. SIKA SHALL NOT BE RESPONSIBLE FOR THE USE OF THIS PRODUCT IN A MANNER TO INFRINGE ON ANY PATENT OR ANY OTHER INTELLECTUAL PROPERTY RIGHTS HELD BY OTHERS. Sale of SIKA products are subject to the Terms and Conditions of Sale which are available at <https://usa.sika.com/en/group/SikaCorp/termsandconditions.html> or by calling 201-933-8300.

### Sika Corporation

201 Polito Avenue  
Lyndhurst, NJ 07071  
Phone: +1-800-933-7452  
Fax: +1-201-933-6225  
[usa.sika.com](http://usa.sika.com)

### Sika Mexicana S.A. de C.V.

Carretera Libre Celaya Km. 8.5  
Fracc. Industrial Balvanera  
Corregidora, Queretaro  
C.P. 76920  
Phone: 52 442 2385800  
Fax: 52 442 2250537



### Product Data Sheet

Sikalastic®-720 One Shot  
January 2021, Version 01.06  
020706201000000021

Sikalastic-720OneShot-en-US-(01-2021)-1-6.pdf

